

Control Valve Maintenance Support System PLUG-IN Valstaff

Introduction

PLUG-IN Valstaff is a valve management system that detects problems with control valves and positioners at the earliest possible stage by monitoring diagnostic parameters and other information from the Smart Valve Positioner, thereby assisting to avoid accident/failure and helping to streamline maintenance tasks by clearly presenting the information required for decision-making on control valve maintenance. The PLUG-IN Valstaff monitors diagnostic information 24 hours a day, 365 days a year by communicating with Azbil Corporation's Smart Valve Positioner, which supports FOUN-DATION[™] fieldbus and HART[®] communication. Based on this diagnostic information, at the first sign of an abnormality, the system sends an alert in order to prompt action before the control valve can cause a problem, allowing continuously safe and secure plant operation. The PLUG-IN Valstaff also supports quick and accurate startup by automating positioner settings that adjust the control valve status, as well as automating step response tests. It also utilizes diagnostic information for routine maintenance, supporting the creation of an appropriate maintenance plan based on the degree of deterioration of control valves.

Function Overview

The PLUG-IN Valstaff, in combination with Azbil Corporation's Smart Valve Positioner, achieves its functions of CV diagnostics parameter monitoring, step response test, and auto-setup by means of integration with a device management system.

Online diagnosis & monitoring while the plant is operating

By collecting diagnostic parameter data from the Smart Valve Positioner and displaying it in a graph during plant operation, the progress of control valve deterioration and the occurrence of abnormalities can be estimated while the plant is operating. The PLUG-IN Valstaff collects data from the positioner and displays the following diagnostics graphs.

1. Total stroke

Displays a chronological graph of the total distance the valve stem has moved as a result of control of the valve travel.

2. Shut-off count

Counts the number of times the valve is completely closed and displays the total close counts in chronological order in a graph.

3. Cycle count

Counts the number of times the control valve motion was reversed and displays it in chronological order in a graph.

4. Travel histogram

Indicates the amount of time the control valve is in that position and the changes that occurred though time in a histogram. R43

5. Maximum travel speed

Constantly measures the operating speed of the control valve in both the opening and closing directions, calculates the maximum speed for each day, and then displays the maximum values for opening and closing directions over time.

6. Stick-slip diagnostics

Analyzes stick-slip occurrence trends.



Figure 1. Stick-Slip Diagnostics Screen

7. Trend data

Displays the travel setting of any selected positioner, the actual travel of the control valve, deviation between travel the setting and actual valve travel, the EPM drive signal, and circuit board temperature. Data for up to one week can be displayed in graph form.

8. Po Validity/Max. Friction diagnostics

Displays the current relationship between output air pressure and valve travel in a graph together with the values obtained during auto-setup, which serve as a standard. Each day's output air pressure validity and maximum friction are indicated chronologically in the graph. (Only Smart Valve Positioner 700 series)

9. Air circuit diagnostics

Each day, the amount of shift from the normal values for the EPM drive signal and nozzle back pressure is calculated and displayed chronologically in a graph. (Only Smart Valve Positioner 700 series)

10. Supply Pressure

Displays the maximum value and minimum value of supply pressure per day in chronological order in a graph. (Only Smart Valve Positioner 700 series)

11. Zero Point Travel

Periodically updates the values for maximum and minimum travel when the valve is fully closed, and displays the maximums and minimums of each day in a chronological graph. (Only Smart Valve Positioner 700 series)

12. Temperature

Periodically updates the temperature measured by the temperature sensor on the electronics board of the positioner, and displays the maximum and minimum temperature of each day in chronological order in a graph. (Only Smart Valve Positioner 700 series)

13. A set of online diagnostic windows

Frequently used online diagnostic windows can be grouped to display a set of windows for individual control valves.



Figure 2. A set of control valve online diagnostic windows

14. Valve Condition Viewer

Displays accumulated online diagnostic results in a table. The results can be sorted and filtered by diagnostic items to show organized information about the current control valve condition.

Home Option																	
			. 19			Y Nak		Group Name		1.00							
Start 11/2017	Period	(×	>	/ice	C Rest	Y.	Basic	v								
End 16/2018	0 12 ~	Month(s) Uz	date Back F	Forward Heat	rical Compariso	" × Beet	Fiber	C) Group Se	tine	CSVO.	ADLE .						
	Diapla	y Period			Graph	Cred	c Laber	Column S	attings	Outp	1						
1		Total	Stroke	94	Count	Cycle	Court	Mas Tope	el Speed				Sick-Si	0			Trend
Derice Tag	Target for Comparison	Difference	End Value	Difference	End Value	Difference	End Value	Nax.+	Max	YX	High Alarm Count	High Alerm End Court	Medium Alerm Court	Nedium Alerm End Court	Low Alerm Court	Low Alerm End Count	Set Poin Max
		5	*	Stre(s)	Size(s)	firm(s)	time(s)	3.6	2.6		firm(s)	firre(s)	time(s)	fine(s)	time(s)	time(s) ·	2
1 PC		5,980,657.0	19.615.938.9	3	18	5	34	101.35	-64.79	9.33	0	3					140
2 FC		1,537,425,4	1,572,409.3	499	525	153	199	178.70	-338.98	48.79	385	19					129
3 FC		1.506.465.2	1,718,538,2	198,149	195,168	6	99	201.38	-193.06	43.94	378	43					99.
4 LC		1,470,810.5	3,297,081.5	11,288	11,344	88	153	46.86	-39.52	13.74	55	6					105
5 PC		1,440,063.3	2,360,282,0	2	78	7	117	70.86	-47.48	13.65	31,490	15					105
6 FC		1,434,868.1	2,264,852,7	5,463	10.024	1,934	2,144	211.44	-192.69	64.65	97,427	171					105
7 LC		1,373,683,1	2,687,900.0	1,105	3,273	2,496	4,157	184.58	-39.97	14,71	12	2					104
8 FC		1,266,863.3	3,716,313,4	4,911	23.232	5.122	9,296	88.15	-189.95	26.52	153	14					145
9 TC		1,146,584,8	2,032,636,4	75,903	122,505	4	27	42.57	-40.70	14.72	168	9					100.
ID FC		866.413.5	1,758,436.3	79	143	0	34	259.65	-930.73	23.88	500	15					105
11 TC		661,777.5	1.053,469.1	4,743	7,968	4	39	43.55	-41.99	12.74	152	11					100
12 FC		645.079.0	726,951,1	78,579	86,578	4	36	213.07	-172.56	29.69	1,536	66					100.
13 FC		568,196.3	736.061.5	47	204	58	154	220.56	-200.59	48.45	2,904	102					105
14 PC		360,625,3	1.917.386.5	80	209	14	127	60.38	-39.65	13.85	24	7					104
IS FC		291,494,1	564,905.7	38	105	4	45	204.12	-172.55	31.62	1,630	74					99.
IS FC		261,706.6	379,875,2	24	129	14	81	209.45	-192.01	31.84	1,442	53					105
17 TC		252,298.7	451,362.5	2,738	4,913	39	55	123.99	-186.50	12.00	86	10					105
IB FC		226.181.5	267,509.5	104,997	108,271	8	65	213.47	-188.57	34.06	1,343	12					104
19 FC		225,723.6	275,254.3	41	92	32	120	210.96	-201.50	40.39	2,405	82					105
E FC		219,403.6	427,577.9	1,171	2,009	11	117	195.98	-331.81	49,20	48,415	113					125
ET FC		168.042.8	636,116,7	33,615	78.878	8	65	212.51	-185.00		1,207	40					100
2 FC		163.850.8	350,606.6	1,123	1,212	8	34	201.89	-176.74		559	32					104
FC FC		162,631.3	200,421.0	39	93	4	39	203.22	-171,71	24.94	2,835	93					99.
R FC		160,476.1	272,231.8	25	56	4	34	120.99	-215.75	5.70	0	3					99.
IS FC		128.085.9	216,766.7	57	127	10	37	85.31	-65.96	9,26	0	2					105
IS FC		123,783,2	203,907.0	36	89	4	41	204.95	-172.55	31.04	1,862	61					100
7 FC		123.001.3	295,258.3	847	912	6	32	203.88	-182.88		995	43					105
14 m																	

Figure 3. Valve Condition Viewer

By drawing monthly trend with accumulated online diagnostic result for multiple Control Valves, a CV which is different behavior compared to the other Valves can be visualized.



Figure 4. Monthly trend of Valve Condition Viewer

Offline Valve Test

A step response test or a valve signature test can be used to diagnose the condition of control valves when the plant is not operating.

1. Step Response Test

When the plant is not operating, the user can check the response of the control valve to changes by making step changes in the travel setting. The result is displayed in a graph that indicates slight changes that cannot be found by a visual check. The result is overlapped with past results for comparison, which is useful to find control valve deterioration and other problems.



Figure 5. Step Response test Screen

Tests can be executed concurrently as well as consecutively for multiple valves, making use of a limited amount of time (Figure 6).

Control valve performance can be evaluated with quantitative dynamic characteristics data obtained from the test, such as time constants, delay time, and settling time, and by comparing the data with past results. The evaluation can be output as a report (Figure 7).



Figure 6. Diagram of step response testing

Note: In case of running this software on InnovativeField Organizer, this step response test can be executed for multiple Control valves simultaneously.



Figure 7. Step Response Test Result Comparison Report

2. Valve Signature Test

When the plant is not operating, a valve signature test can be executed. This test ramps the control valve at low speed in both directions to the fully closed and fully open positions in order to diagnose the condition of each part of the valve, utilizing the characteristics data obtained from the output air pressure of the actuator and from valve travel.

The result, which are displayed in the graph, can be used to detect deterioration or other problems in the control valve. This test can be executed for several control valves consecutively.

(Only Smart Valve Positioner 700 series)



Figure 8. Valve Signature Screen

Testing of emergency shutoff valves

A partial stroke test (PST) or full stroke test (FST) can be used to diagnose the condition of emergency shutoff valves.

1. Partial Stroke Test (PST)*

When the plant is operating, PLUG-IN Valstaff executes a partial-stroke low-speed ramp operation for emergency shutoff valves. Equipment failure can be detected from the results.

The test results are indicated in a graph. By comparing the results with past results, the user can find deterioration and other problems with emergency shutoff valves. This test can be executed for several emergency shutoff valves consecutively.

2. Full Stroke Test (FST)*

When the plant is not operating, PLUG-IN Valstaff opens and closes emergency shutoff valves to their full extent to check if they operate properly.

The test results are indicated in a graph. By comparing the results with past results, the user can find deterioration and other problems with emergency shutoff valves.

This test can be executed for several emergency shutoff valves consecutively.

- These tests are available when PLUG-IN Valstaff is used with the following 700 Series Smart ESD Devices provided by Azbil Corporation:
 - Model AVP77_ (analog signal 4-20 mAdc)
 - Model AVP78_ (analog signal 0–20 mAdc)
 - Model AVP79_ (discrete signal 0/24 Vdc)
 - Model AVP703

Auto-setup

The PLUG-IN Valstaff's auto-setup function automatically adjusts the positioner.

The user can monitor the behavior of control valves during auto-setup, checking if there is abnormality in the auto adjustment process.

Also, the stroke time and hysteresis data collected during auto-setup can be compared with the past test data. This comparison provides an easy way to judge deterioration and the occurrence of abnormalities in the control valve.



Figure 9. Auto-setup Screen

Device Memo

A memo can be created for individual control valves with a simple operation and can be opened from the device tree for easy reference. The user can use device memos for purposes such as recording the installation date, adjustment history, or abnormal conditions, in order to manage control valves.

System Configuration

The PLUG-IN Valstaff works in conjunction with the InnovativeField Organizer[™] (IFO) device management system made by Azbil Corporation or with the PRM[®] (Plant Resource Manager) made by Yokogawa Electric Corporation.

With Advanced-PS (TDCS3000)

By operating the PLUG-IN Valstaff on IFO, it is possible to manage control valves with a HART communicationcompatible Smart Valve Positioner model AVP202/AVP302/ SVX102/AVP307/AVP701/AVP702/AVP77_/AVP78_/ AVP79_.

For details on system configuration, refer to the specification sheet for IFO (SS2-IFO430-0001).



Figure 10. PLUG-IN Valstaff Configuration for Advanced-PS/TDCS3000

With Harmonas-DEO

By operating the PLUG-IN Valstaff on IFO, it is possible to manage control valves with a Smart Valve Positioner by using HART communication.

For details on system configuration, refer to the specification sheet for IFO (SS2-IFO430-0001).





IFO system configuration, which is independent of DCS model

The PLUG-IN Valstaff can be used in conjunction with IFO independent from DCS by using HNU (HART Network Unit). In this case, the PLUG-IN Valstaff can manage control valves with HART communication-compatible Smart Valve Positioner model AVP202/AVP302/SVX102/AVP307/AVP701/AVP702/AVP77_/AVP78_/AVP79_. A HART modem or controller compatible with HART-IP can be used as an interface unit instead of HNU. For details on system configuration, refer to the specification sheet for IFO (SS2-IFO430-0001).



Figure 12. IFO system configuration, which is independent of DCS vendor and model

When Combined with Yokogawa Electric Corporation's PRM

The PLUG-IN Valstaff control valve maintenance support system can be used in conjunction with Yokogawa Electric Corporation's Plant Resource Manager (PRM).



Figure 13. PLUG-IN Valstaff configuration on PRM Server

System Specifications

Maximum Number of Connected Smart Valve Positioners

The maximum number of positioners that can be managed by the PLUG-IN Valstaff is shown below. It is dependent on the communication protocol.

System	Communication protocol	Maximum number of managed units		
Azbil Corporation's	HART			
device management system IFO	Foundation fieldbus	1000 *1		
Yokogawa Electric	HART	500 *1		
Corporation's PRM	FOUNDATION fieldbus	500 1		

*1: The sum of FOUNDATION fieldbus devices and HART devices.

Data collection Specifications

Table 1. With IFO

		Stick-slip diagnostics:	400 s	
		Total stroke:	1 day *2	
		Maximum travel speed:		
		Total shut-off count:	1 day *2	
		Cycle count:	1 day *2	
		Po Validity/Max. Friction diagnostics:	1 day *2 *4	
Diagnostic p	arameter	Air circuit diagnostics:	1 day *2 *4	
update inter	val	Supply Pressure:	1 day *2 *4	
		Zero Point Travel:	1 day *2 *4	
		Travel histogram:	1 Month	
		Set Point (from DCS OP) and Valve opening:	Fastest 1 s	
		Output Air Pressure:	Fastest 1 s *2 *4	
		Deviation:	Fastest 1 s $^{\ast 2}$	
		Temperature:	Fastest 1 s *2	
	FOUNDATION fieldbus	Model AVP703	Fastest 50 ms	
Valve test*5	communica- tion	Model AVP303	85 ms	
data sampling cycle	HART	Model AVP701/702/ AVP77_/78_/79_	Fastest 50 ms	
	communica-	Model AVP302/202	85 ms	
	tion	Model AVP307	85 ms	
Device cond ing interval	ition monitor-	Fastest 1 s *2		

Table 2. With PRM

		Stick-slip diagnostics:	400 s *1 *2	
-		Total stroke:	1 day *2	
		Maximum travel speed:	1 day *2	
		Total shut-off count:	1 day *2	
		Cycle count:	1 day *2	
		Po Validity/Max. Friction diagnostics:	1 day *2 *4	
		Air circuit diagnostics:	1 day *2 *4	
Diagnostic p	arameter	Supply Pressure:	1 day *2 *4	
update inter		Zero Point Travel:	1 day *2 *4	
		Travel histogram:	1 month	
		Set Point (from DCS OP) and Valve opening:	Fastest 1 s *1 *2	
		Output Air Pressure:	Fastest 1 s *1 *2 *4	
		Deviation:	Fastest 1 s *1 *2	
		Temperature:	Fastest 1 s *1 *2	
		Model AVP703	Fastest 50 ms	
Valve test ^{*5}	fieldbus communication	Model AVP303	85 ms	
data sampling		Model AVP701/702/ AVP77_/78_/79_	Fastest 50 ms	
cycle	HART communication	Model AVP302/202	Fastest 5 s *3	
		Model AVP307	85 ms	
Device condition monitoring interval		300 s *2		

- *1: In case of Valstaff running on PRM, the functions may not be available or specifications may be different depending on the performance of PRM Field Communication Server, HART communication performance every IO of CENTUM, and how to assign HART dynamic parameters by IOM Builder.
- *2: Interval may require adjustment depending on the number of valve positioners connected.
- *3: Depending on the communication performance, a simple test may be required instead of a step response test.
- *4: Only Smart Valve Positioner 700 series
- *5: Valve test refers to the step response test, valve signature test, partial stroke test, and full stroke test.

Table 3. Application Specifications

			PLUG-II	V Valstaf	f for IFO			PLUG-IN	l Valstaff	for PRM	
		F	F		HART		F	F		HART	
	ltem I		Model AVP703	Model AVP302 AVP202	Model AVP701 AVP702	Model AVP307 *2	Model AVP303	Model AVP703	Model AVP302 AVP202	Model AVP701 AVP702	Model AVP307 *2
Positioner setup	Auto Setup	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	~	\checkmark	1	\checkmark	\checkmark
	Valve Signature *1		1		\checkmark			\checkmark		\checkmark	
Offline	Step Response Test	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark		\checkmark	\checkmark
Disgnostics in plant shutdown	Sequential automatic execution of Step Response Test to multiple CSv	1	~	~	1	1	~	~		~	\checkmark
	Simultaneous execution of Step Response Test to multiple CVs	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark					
	Total Stroke	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark
	Total shut-off count	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark
	Cycle Count	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark
	Travel histogram	\checkmark	1	\checkmark	\checkmark	\checkmark	\checkmark	1	\checkmark	\checkmark	\checkmark
	Max Travel Speed	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark
	Stick-slip diagnostics	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark
	Zero point (Shut off) diagnostic	\checkmark	1	\checkmark	\checkmark	\checkmark	1	\checkmark	\checkmark	\checkmark	\checkmark
Online Diagnostics	Deviation diagnostics between Input and Travel	√ *3	√*3	√ *3	√ *3	√ *3	✓ *4	√ *4	✓ *4	\checkmark^{*4}	✓ *4
in plant operation	Output air pressure validity *1		1		\checkmark			1		\checkmark	
operation	Max frictional force *1		\checkmark		\checkmark			\checkmark		\checkmark	
	Supply air pressure *1		\checkmark		\checkmark			\checkmark		\checkmark	
	Positioner air circuit abnormality *1		\checkmark		\checkmark			\checkmark		\checkmark	
	Trend data such as Input, Travel, Deviation, EPM drive signal	√ *3	√ *3	√ *3	√ *3	√ *3	✓ *4	✓ *4	✓ *4	\checkmark^{*4}	✓ *4
	Summary Report generation for Online Diagnostics parameters	\checkmark	~	~	\checkmark	\checkmark	1	~	1	1	\checkmark
Positioner	Param. Backup	\checkmark	1	\checkmark	\checkmark	\checkmark	1	\checkmark	1	\checkmark	\checkmark
Param. Backup	Param. Backup for many AVPs in bulk	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark

*1: available for the model AVP701/AVP702/AVP703 only

*2: Require PLUG-IN Valstaff R43 or later in case of use in combination with the model AVP307.

*3: Data collection on best effort with fastest 1 second scan.

*4: With Exaopc communication, Data collection on best effort with fastest 1 second scan. (With communication via PRM, data sampling interval is 1 hour because of performance constraint)

Note: Require PLUG-IN Valstaff R43 or later to execute this function.

Target Smart Valve Positioner

Table 4. Smart Valve Positioner 300/200 series

Model number	Internal software version	
Model AVP302	Ver 2 Devileter	
Model AVP202	Ver. 3.D or later	
Model AVP303	W 21 14	
Model AVP203	Ver. 2.1 or later	
Model AVP307	Ver. 7.0 or later	

Table 5. Smart Valve Positioner 700 series

Model number	Internal software version
Model AVP701/702/ AVP77_/78_/79_	Ver. 2.1 or later
Model AVP703	Ver. 2.5 or later

For detailed Smart Valve Positioner specifications, refer to the specification sheet for each product shown below.

the specification sheet for each	h product shown belo
Model AVP302:	SS2-AVP300-0100
Model AVP202:	SS2-AVP200-0100
Model SVX102:	SS2-SVX100-0100
Model AVP307:	SS2-AVP307-0100
Model AVP303/203:	SS2-AVP303-0100
Model AVP701/702:	SS2-AVP702-0100
Model AVP77_/78_/79_:	SS2-AVP772-0100
Model AVP703:	SS2-AVP703-0100

Operating Environment

The PLUG-IN Valstaff works on Azbil Corporation's IFO or Yokogawa Electric Corporation's PRM R3.10 or later.

Table 6. Computer platform

System/soft- ware package	Operating System
InnovativeField Organizer R43	Windows 7 Professional SP1 64-bit Windows 10 Pro (64-bit) *
RPM R3.10/	Windows Server 2008 Standard Edition Service Pack 2 (32-bit)
R3.11/R3.12/ R3.20/R3.30/ R3.31/	Windows Server 2008 Standard Edition R2 Service Pack 1 (64-bit)
R4.01/R4.02	Windows 7 Professional Edition Service Pack 1 (64-bit)
	Windows 10 Enterprise 2016 LTSB (64bit) Windows Server 2016 Standard Edition (64bit)

 For details, refer to the specification sheet for InnovativeField Organizer (R43).

License System

Table 7. PLUG-IN Valstaff base license

	Model number	Description
	FNV-IFV4XE01	PLUG-IN Valstaff R4x License 16 TAG entry edition
	FNV-IFV4XE02	PLUG-IN Valstaff R4x License 25 TAG
	FNV-IFV4XE05	PLUG-IN Valstaff R4x License 50 TAG
License for	FNV-IFV4XE10	PLUG-IN Valstaff R4x License 100 TAG
number of device	FNV-IFV4XE20	PLUG-IN Valstaff R4x License 200 TAG
connection	FNV-IFV4XE30	PLUG-IN Valstaff R4x License 300 TAG
	FNV-IFV4XE50	PLUG-IN Valstaff R4x License 500 TAG
	FNV-IFV4XE75	PLUG-IN Valstaff R4x License 750 TAG
	FNV-IFV4XEA0	PLUG-IN Valstaff R4x License 1000 TAG

Table 8. PLUG-IN Valstaff DMS (Device Management System) connection license

	Model number	Description
License ioi	FNV-IFV4XE-A	PLUG-IN Valstaff R4x DMS connect License for IFO
DMS connection	FNV-IFV4XE-B	PLUG-IN Valstaff R4x DMS connect License for PRM

Table 9. PLUG-IN Valstaff TAG extension license

After PLUG-IN Valstaff is installed, this license is used to increase the number of connected devices.

	Model number	Description
	FNV-IFV4XEP1	PLUG-IN Valstaff R4x TAG extension license 16to25
	FNV-IFV4XEP2	PLUG-IN Valstaff R4x TAG extension license 25to50
	FNV-IFV4XEP3	PLUG-IN Valstaff R4x TAG extension license 50to100
License for number	FNV-IFV4XEP4	PLUG-IN Valstaff R4x TAG extension license 100to200
of device extension	FNV-IFV4XEP5	PLUG-IN Valstaff R4x TAG extension license 200to300
	FNV-IFV4XEP6	PLUG-IN Valstaff R4x TAG extension license 300to500
	FNV-IFV4XEP7	PLUG-IN Valstaff R4x TAG extension license 500to750
	FNV-IFV4XEP8	PLUG-IN Valstaff R4x TAG extension license 750to1000

External Storage

Automatic backup and external storage is available for control valve diagnostic data collected by PLUG-IN Valstaff operating in IFO. Please use the external storage to prevent lack of data.

For automatic back-up, the user can use the following operability-confirmed external storage media.

- Tanberg Data Inc. RDX QuikStor External USB Docking Station Model: 8782
- Tanberg Data Inc. RDX QuikStor Cartridge (Memory: 1 TB) Model: 8586

Tanberg Data Inc. web site:

http://www.tandbergdata.com/us/

Notes

When using external storage for automatic back-up, keeping your PC safe is a necessity. However, please do not install anti-virus software on the PC used for IFO. Instead, do virus-checking remotely from another PC. Also, if an external storage device whose operation we have not checked is used, Azbil Corporation cannot guarantee its operation or the integrity of the data. If the lack of a guarantee is acceptable and an external storage device which we have not checked is used, please use a device that meets the

- following conditions at a minimum.
 This device does not require special software (do not install software other than Azbil products on the PC used for IFO).
- This device does not incorporate a security function.

About icons for safety precautions

The safety precautions described in this document are indicated by the following icons.



\bigcirc	The indicated	action is	prohibited.
------------	---------------	-----------	-------------

Be sure to follow the indicated instructions.

Safety precautions

		CAUTION			
	Before wiring, be s devices that requir Failure to do so ma	e power shu	toff during wiring.		
\bigotimes	If an explosion-proof field device is used, never open its cover while it is running (while power is supplied). Doing so may result in an electric shock. For handling of this type of device, see the user's manual for the device.				
8	Do not touch electrically charged parts such as the power supply terminals. Doing so may result in an electric shock.				
	Back up data and c Failure to do so ma program malfunct	y result in co			
\bigcirc	Do not install any a Check for viruses re				
\otimes	external network s rate intranet. If the PC is infected	n software is uch as the In d by a virus, t	to be installed to an ternet or a corpo-		
\otimes	Do not install any a below on the PC u application softwa • Device manage software • PLUG-IN Valstaff	applications pon which the re is to be inseminate ment system f application 5B hard disk ding (if necessed ding that Azbill er any failure	except those listed ne PLUG-IN Valstaff stalled. and associated software drive used for data ssary) Corporation's war- es resulting from		
•	Before connecting operators in the co operate. Unexpected device	ontrol room t	hat devices will be		

•	Before executing offline diagnostics, inform work- ers in the vicinity of control valves that the diagnos- tics will make the valves open and close regardless of signals from the controller. Unexpected valve opening or closing can injure workers.			
•	Before executing full stroke tests, inform workers in the vicinity of control valves that the tests will make the valves open and close regardless of signals from the controller. Unexpected valve opening or closing can injure workers.			
•	Before calibrating or adjusting the positioner, changing settings, or performing other related operations, check that the intended operation will not affect the operation of the plant and change the mode to "out of service."			
	Before executing AutoSetup, inform workers in the vicinity of control valves that AutoSetup will open the valves from the fully closed position to the fully open position. Unexpected valve opening or closing can injure workers.			
	When connecting the hard disk drive to another PC, perform a virus check before reconnecting it to the device management system.			
	Before using PLUG-IN Valstaff online while devices are operating, please make sure that HART commu- nication will not affect the host control system.			

CAUTION

-Memo-

-Memo-

• Valstaff and InnovativeField Organizer are trademarks of Azbil Corporation.

- PRM® is a trademark of Yokogawa Electric Corporation in the USA and other countries.
- FOUNDATION is a trademark of FieldComm Group.
- HART[®] is a registered trademark of FieldComm Group.
- Windows 7, Windows 10 Pro, Windows Server 2008, and Windows Server 2016 are trademarks of Microsoft Corporation in the USA and other countries.
- Other product names, model nos., and company names may be trademarks of the respective company.

Please read "Terms and Conditions" from the following URL before ordering and use. https://www.azbil.com/products/factory/order.html

Specifications are subject to change without notice.

Azbil Corporation Advanced Automation Company

1-12-2 Kawana, Fujisawa Kanagawa 251-8522 Japan URL: https://www.azbil.com/ azbil